



AIR PURIFICATION SYSTEMS AND SERVICES

# Certificate of Efficiency

Coros SA test every device before packaging and declare that IAQ series filter up to 99.99 % at 0,5  $\mu\text{m}$  ,and 99,976 % at 0,3  $\mu\text{m}$  . ( PM 2.5 ) .  
Tests filters are made in an independent engineering company .

IAQ art  
Serial N°

serie : IAQ-32 HEPA VOC  
hepa air filtration system  
COROS  
Serial n°  
32170001504  
www.coros.ch Tel. +41 91 829 2664

CE  
QR code

Test device QC Signature

<b>Flow Rate (cfm)</b>	<b>350 cfm</b>
<b><math>\Delta p</math> ( H2O )</b>	<b>1.823</b>
<b>Size Range ( <math>\mu\text{m}</math> )</b>	<b>Fractional Efficiency (%)</b>
<b>0.1–0.15</b>	<b>99.960</b>
<b>0.15–0.2</b>	<b>99.967</b>
<b>0.2–0.3</b>	<b>99.976</b>
<b>0.3–0.5</b>	<b>99.988</b>
<b>0.5–0.7</b>	<b>99.991</b>
<b>0.7–1.0</b>	<b>100.000</b>

COROS SA  
SWITZERLAND

